



TEST RESULTS

22.0 SUMMARY OF RESULTS

Test Method	Test Conditions	Test Conclusion
Air Infiltration Test (ASTM E283 and TAS 202)	1.57 psf & 6.24 psf	PASS
Uniform Static Load Test (ASTM E330 and TAS 202)	+ 70 and - 80 psf Design Pressure	PASS
Forced Entry Resistance Test (TAS 202 [SFBC 3603.2 (b) 5])	300-lb.	PASS
Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb, 2 x 4 @ 50ft/sec	PASS
Cyclic Load Test (TAS 203 and ASTM E1996)	+ 70 and - 80 psf Design Pressure	PASS

ENGINEER OF RECORD

5/4/2007

Vinu J. Abraham, P.E.

FL Reg. #53280